



**Declaration of Performance**  
**N° 01155-PYRO-SAFE-FLAMMOTECT-A**  
**PYRO-SAFE FLAMMOTECT-A**

Date: 27.01.2015  
 Rev. 02  
 Page 1 of 1

*Unique identification code of the product type*  
**PYRO-SAFE FLAMMOTECT-A**

*Intended use:*  
**Ablative fire stopping product used in penetration seals**

*Producer*  
**svt Brandschutz Vertriebsgesellschaft mbH International**  
**Gluesinger Strasse 86**  
**D - 21217 Seevetal**  
**Germany**

*System for assessing and verifying constancy of performance*  
**System 1**

*European Assessment Document*  
**ETAG 026-2:2011-10-14**

*European Technical Assessment*  
**ETA-14/0418 of 04.12.2014**

*Technical Assessment Body*  
**Deutsches Institut für Bautechnik (DIBt), Berlin**

*The notified body*  
**Materialprüfanstalt für das Bauwesen Braunschweig, code number 0761**

*Declared performance*

| Essential characteristics        | Performance                                                                                                                                  | Harmonised technical specification |
|----------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| Reaction to fire                 | <b>Class E</b>                                                                                                                               | EN 13501-1                         |
| Fire resistance                  | <b>Class EI 30</b><br>of a penetration seal (with mineral wool; see Annexes 1 and 17-22 of ETA-14/0418 for details)                          | EN 13501-2                         |
|                                  | <b>Class EI 60</b><br>of a penetration seal (with mineral fibre board single-layer; see Annexes 1 and 2-6 of ETA-14/0418 for details)        |                                    |
|                                  | <b>Class EI 60</b><br>of a penetration seal (with mineral wool; see Annexes 1 and 23-27 of ETA-14/0418 for details)                          |                                    |
|                                  | <b>Class EI 90</b><br>of a penetration seal (with mineral wool; see Annexes 1 and 28-32 of ETA-14/0418 for details)                          |                                    |
|                                  | <b>Class EI 90</b><br>of a penetration seal (without mineral wool; see Annexes 1 and 33 of ETA-14/0418 for details)                          |                                    |
|                                  | <b>Class EI 120</b><br>of a penetration seal (with mineral fibre boards double-layer; see Annexes 1 and 7-11 of ETA-14/0418 for details)     |                                    |
|                                  | <b>Class EI 240</b><br>of a penetration seal (with mineral fibre boards quadruple-layer; see Annexes 1 and 12-16 of ETA-14/0418 for details) |                                    |
| Emission of dangerous substances | no dangerous substances                                                                                                                      | ETAG 026-2                         |
| Durability and serviceability    | Use category type X                                                                                                                          | EOTA TR 024                        |

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above  
 DoP online available at [www.svt.de](http://www.svt.de).

Signed for and on behalf of the manufacturer by:

i.V. Christian Meyer-Korte  
 Head of Product Management

i.V. Andree Schober  
 Head of chemical department